

**Appendix M Preferred Pollution Control Combination**



Calculation of Hexavalent Chromium Emission Rates  
Preferred Pollution Control Combination (as presented in the Action Plan)

Emission Rate Calculations for the Final Preferred Pollution Control Combination (E\_R9)

Source Type	before RC			after RC	before RC			After RC-CFM only								Total			
	B01	B24	B25	B11current	B11	B38current	B38	B08	B10	B32	B33	B34	B35	C79	C80				
Current Base Case Emission Rate (g/s)	3.55E-05			1.51E-04		3.32E-05		2.05E-06	2.39E-06	2.39E-06		2.39E-06	2.39E-06	2.04E-06	2.04E-06	2.35E-04			
2016 Reconfiguration Base Emission Rate (g/s)		1.78E-05	1.78E-05		7.53E-05		3.32E-05		1.19E-06	1.19E-06	2.05E-06	1.19E-06	1.19E-06	2.04E-06	2.04E-06	1.55E-04			
<b>Uncertainty Applied</b>		1.23	1.23		1.55		1.55		1.52	1.52	1.52	1.52	1.52	1.52	1.52				
2016 Base RC Emission Rate (g/s) with Uncertainty Factors applied		2.18E-05	2.18E-05		1.17E-04		5.14E-05		1.82E-06	1.82E-06	3.12E-06	1.82E-06	1.82E-06	3.10E-06	3.10E-06	2.28E-04			
Combination ID	Option Description		B01	B24	B25	B11	B11	B38current	B38 (combined FH Stack)	B08	B10	B32	B33	B34	B35	C79	C80	Total	
E_R9	Reconfiguration + forehearth sections incorporating more accurate combustion control skids and construction of front end superstructures (14) + re-engineering exhaust stacks impacted by reconfiguration (15)						prototype		NA										
	Description of Reduction Component						14				Result of 14	Result of 14		Result of 14	Result of 14				
	Individual Reduction Identification #						50%			0%	50%	50%	0%	50%	50%	0%	0%		
	Reduction Efficiency			0%	0%														
	Additional Reduction Efficiency																		
Comments		Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	Source ER (g/s)	TotalER (g/s)	
RC+14+partial 15			2.18E-05	2.18E-05		Exhausted out B38		1.10E-04		9.08E-07	9.08E-07	3.12E-06	9.08E-07	9.08E-07	3.10E-06	3.10E-06	1.66E-04		

Explanation of Calculations

**Furnace:**  
The reconfiguration plans include taking the existing furnace (T107) out of service and restarting the T105 furnace. The emission rate for T105 furnace is estimated (conservatively) to be the same as the existing furnace as they will employ similar technologies and the same glass formulation. However, the emissions will be discharged from two existing (currently out of service) stacks B24 and B25. The only change to the furnace emission rates is the incorporation of the uncertainty factor (23%) which is calculated using the Methodology outlined in the Alberta Air Monitoring Directive, Chapter 5: Quality System.

**Forehearths:**  
The reconfiguration plans include removal of approximately half of the existing conventional forehearth which currently exhausts through stack B11 (B11current), therefore the current emission rate is divided by 2 to prior to the application of any reduction efficiencies related to the control option. There are no planned changes to the CFM forehearth (exhausting through B38current). An uncertainty factor (55%) is applied to the emission rates from both sections of forehearth. The uncertainty factor is calculated using the Methodology outlined in the Alberta Air Monitoring Directive, Chapter 5: Quality System. The technology to be implemented as part of this pollution control option (E\_R9) is the installation of more accurate combustion control skids and construction of front end superstructures in the remaining conventional forehearth. Therefore, the reduction efficiency of 50% for the technology is applied only to the emission rate associated with the conventional forehearth (adjusted for downsizing). After the reconfiguration and implementation of this pollution control combination, all forehearth emissions will be exhausted through a single location at the current B38 stack.

Example Calculation for the changes to the Conventional Forehearth emissions (B11current)

New B11 ER, g/s= (Current B11 forehearth rate, g/s) / 2 (for reduction of forehearth area) x (Source Testing uncertainty factor of 1.55)

New B11 ER, g/s= [0.000151, g/s / 2] x 1.55

New B11 ER, g/s= 1.17E-04

B11 ER after technologies applied = New B11 ER x (1 - reduction efficiency of technologies)

B11 ER after technologies applied = New B11 ER, g/s x (1 - 50%)

B11 ER after technologies applied = 5.84E-05

After Reconfiguration and implementation of the control technologies, all forehearth emissions will be exhausted through a new stack at the B38 location (here referred to above as the "B38 Combined FH" stack)

B38 Combined FH stack ER, g/s= [B11 ER after technologies applied] + [B38 current ER x Source testing uncertainty factor of 1.55]

B38 Combined FH stack ER, g/s= 0.0000584 + 0.00005145

B38 Combined FH stack ER, g/s= 1.10E-04

**General Ventilation Exhausts:**

The reconfiguration plans include removal of approximately half of the existing conventional forehearth which is believed to be the greatest contributor to emissions leaving the facility through most of the general ventilation exhausts. An uncertainty factor (52%) is applied to all of the general ventilation emission rates. The uncertainty factor is calculated using the Methodology outlined in the Alberta Air Monitoring Directive, Chapter 5: Quality System. Therefore, the emission rates from 5 of the general ventilation exhaust fans are reduced by 50% based on the conventional forehearth downsizing. The installation of the control technologies on the conventional forehearth is anticipated to reduce the furnace hall emissions by the same reduction efficiency.

**Example Calculation for the changes to General Ventilation Source B32**

New B32 ER, g/s= (current B32 ER, g/s) / 2 (for reduction of forehearth area) x 1.52 (Source Testing Uncertainty Factor) x (1-reduction efficiency for conventional forehearth technology)

New B32 ER, g/s= 0.0000239 / 2 x 1.52 x (1-0.5)

New B32 ER, g/s= 9.08E-07

RC	Reconfiguration in 2016
RE1	Roof exhausters unchanged by process changes
RE2	Roof exhausters affected by process changes

## Calculation of Uncertainty for General Ventilation Sources

	Raw Cr+6	Blank Corrected Cr+6
Source	Concentration	Concentration
	µg/m <sup>3</sup>	µg/m <sup>3</sup>
Source B8	0.2781190	0.1751120
Source B10	0.3577441	0.2588797
Source C80	0.2373759	0.1424255

confidence interval = 0.05 95%  
 number of samples (n) = 3  
 test statistic (t-value) = 4.303 from t-tables.xls  
 sample mean (x) = 0.291 (arithmetic mean)  
 standard deviation (s) = 0.0612 (standard deviation of a sample using STDEV.S function)

sample uncertainty is equal to the mean +/- [t-value x standard deviation (s) / Square root of # of samples (n)]

sample uncertainty = 0.291 +/- 0.15

Uncertainty as a percentage 52%

## Calculation of Uncertainty for Source B38 (with prototype technology)

<b>Using both Data Sets (August 2013 condition #1 and September 2014 Validated Testing)</b>						
Combined Data Sets (values)						
	35.43	28.42	35.72	12.07	11.90	12.46
confidence interval =	0.05		95%			
number of samples (n) =	6					
test statistic (t-value) =	2.571	from t-tables.xls				
sample mean (x) =	22.7	(arithmetic mean)				
standard deviation (s) =	11.82193863	(standard deviation of a sample using STDEV.S function)				
sample uncertainty is equal to the mean +/- [t-value x standard deviation (s) / Square root of # of samples (n)]						
sample uncertainty =	22.7	+/-	12.41			
Uncertainty as a percentage	55%					

## Calculation of Uncertainty for Furnace Source B01

B01 Furnace Data	13-Oct-11	14-Oct-11	14-Oct-11	6-Aug-13	7-Aug-13	7-Aug-13	12-Jun-14	12-Jun-14	12-Jun-14
Hex Cr (ug/s)	37	33	42	46	24	25	38	50	19

only June 2014 data is validated

However, all testing done using same methodology and furnace is considered to be very steady state with no technology/process changes

### Using all 3 Data Sets

confidence interval = 0.05 95%  
 number of samples (n) = 9  
 test statistic (t-value) = 2.306 from t-tables.xls  
 sample mean (x) = 34.8 (arithmetic mean)  
 standard deviation (s) = 10.3682 (standard deviation of a sample using STDEV.S function)

sample uncertainty is equal to the mean +/- [t-value x standard deviation (s) / Square root of # of samples (n)]

sample uncertainty = 34.8 +/- 7.97

Uncertainty as a percentage 23%

## APPENDIX CALCULATING UNCERTAINTY OF MEASUREMENT

A number of samples, say  $n$ , are collected from a given condition for which measurement uncertainty is to be assessed. The purpose is to express measurement uncertainty in a confidence interval with a certain probability, say 95 per cent. In this instance, the wider the confidence interval, the greater is the measurement uncertainty for the method in question.

For practical reasons,  $n = 6$  is considered applicable and the following parameters are to be computed:

$$\bar{x} = \sum_{i=1}^n x_i / n \quad \text{the sample mean,}$$

$$\bar{x}_L = \bar{x} - t_{\alpha/2, n-1} \times s_{\bar{x}} \quad \text{the upper confidence limit of the sample mean,}$$

$$\bar{x}_U = \bar{x} + t_{\alpha/2, n-1} \times s_{\bar{x}} \quad \text{the lower confidence limit of the sample mean,}$$

$$s = \sqrt{\sum_{i=1}^n (x_i - \bar{x})^2 / (n-1)} \quad \text{the sample standard deviation,}$$

$$s_{\bar{x}} = s / \sqrt{n} \quad \text{the standard deviation of the sample mean.}$$

For 95 % confidence interval ( $\alpha = 0.05$ ) and a sample of  $n = 6$ , the test statistic (t-value) is

$$t_{\alpha/2, n-1} = 2.571.$$

The measurement uncertainty is represented by  $\bar{x} \pm t_{\alpha/2, n-1} \times s / \sqrt{n}$ . This is  $\bar{x} \pm 1.05s$  in this case.

As an example: for a sample of 6 observations:  $x_1 = 0.61$ ,  $x_2 = 0.95$ ,  $x_3 = 0.91$ ,  $x_4 = 1.16$ ,  $x_5 = 0.72$ ,  $x_6 = 0.59$ . The mean is 0.82. The standard deviation  $s$  is 0.22. The resulting measurement uncertainty is  $0.82 \pm 0.23$ .

As a rough general rule, it is recommended that the minimum sample size be  $n=6$  for an adequate estimation of uncertainty. The larger the sample size, the more precise the estimation in measurement uncertainty.

**Note:** As the sample size changes, the t-value needs to be changed accordingly. The above calculation is appropriate for a sample size of six. For a larger sample size, other values of the test statistic need to be used.




# t Table

cum. prob	$t_{.50}$	$t_{.75}$	$t_{.80}$	$t_{.85}$	$t_{.90}$	$t_{.95}$	$t_{.975}$	$t_{.99}$	$t_{.995}$	$t_{.999}$	$t_{.9995}$
one-tail	0.50	0.25	0.20	0.15	0.10	0.05	0.025	0.01	0.005	0.001	0.0005
two-tails	1.00	0.50	0.40	0.30	0.20	0.10	0.05	0.02	0.01	0.002	0.001
df											
1	0.000	1.000	1.376	1.963	3.078	6.314	12.71	31.82	63.66	318.31	636.62
2	0.000	0.816	1.061	1.386	1.886	2.920	4.303	6.965	9.925	22.327	31.599
3	0.000	0.765	0.978	1.250	1.638	2.353	3.182	4.541	5.841	10.215	12.924
4	0.000	0.741	0.941	1.190	1.533	2.132	2.776	3.747	4.604	7.173	8.610
5	0.000	0.727	0.920	1.156	1.476	2.015	2.571	3.365	4.032	5.893	6.869
6	0.000	0.718	0.906	1.134	1.440	1.943	2.447	3.143	3.707	5.208	5.959
7	0.000	0.711	0.896	1.119	1.415	1.895	2.365	2.998	3.499	4.785	5.408
8	0.000	0.706	0.889	1.108	1.397	1.860	2.306	2.896	3.355	4.501	5.041
9	0.000	0.703	0.883	1.100	1.383	1.833	2.282	2.821	3.250	4.297	4.781
10	0.000	0.700	0.879	1.093	1.372	1.812	2.228	2.764	3.189	4.144	4.587
11	0.000	0.697	0.876	1.088	1.363	1.796	2.201	2.718	3.106	4.025	4.437
12	0.000	0.695	0.873	1.083	1.356	1.782	2.179	2.681	3.055	3.930	4.318
13	0.000	0.694	0.870	1.079	1.350	1.771	2.160	2.650	3.012	3.852	4.221
14	0.000	0.692	0.868	1.076	1.345	1.761	2.145	2.624	2.977	3.787	4.140
15	0.000	0.691	0.866	1.074	1.341	1.753	2.131	2.602	2.947	3.733	4.073
16	0.000	0.690	0.865	1.071	1.337	1.746	2.120	2.583	2.921	3.686	4.015
17	0.000	0.689	0.863	1.069	1.333	1.740	2.110	2.567	2.898	3.646	3.965
18	0.000	0.688	0.862	1.067	1.330	1.734	2.101	2.552	2.878	3.610	3.922
19	0.000	0.688	0.861	1.066	1.328	1.729	2.093	2.539	2.861	3.579	3.883
20	0.000	0.687	0.860	1.064	1.325	1.725	2.086	2.528	2.845	3.552	3.850
21	0.000	0.686	0.859	1.063	1.323	1.721	2.080	2.518	2.831	3.527	3.819
22	0.000	0.686	0.858	1.061	1.321	1.717	2.074	2.508	2.819	3.505	3.792
23	0.000	0.685	0.858	1.060	1.319	1.714	2.069	2.500	2.807	3.485	3.768
24	0.000	0.685	0.857	1.059	1.318	1.711	2.064	2.492	2.797	3.467	3.745
25	0.000	0.684	0.856	1.058	1.316	1.708	2.060	2.485	2.787	3.450	3.725
26	0.000	0.684	0.856	1.058	1.315	1.706	2.056	2.479	2.779	3.435	3.707
27	0.000	0.684	0.855	1.057	1.314	1.703	2.052	2.473	2.771	3.421	3.690
28	0.000	0.683	0.855	1.056	1.313	1.701	2.048	2.467	2.763	3.408	3.674
29	0.000	0.683	0.854	1.055	1.311	1.699	2.045	2.462	2.756	3.396	3.659
30	0.000	0.683	0.854	1.055	1.310	1.697	2.042	2.457	2.750	3.385	3.646
40	0.000	0.681	0.851	1.050	1.303	1.684	2.021	2.423	2.704	3.307	3.551
60	0.000	0.679	0.848	1.045	1.296	1.671	2.000	2.390	2.660	3.232	3.460
80	0.000	0.678	0.846	1.043	1.292	1.664	1.990	2.374	2.639	3.195	3.416
100	0.000	0.677	0.845	1.042	1.290	1.660	1.984	2.364	2.626	3.174	3.390
1000	0.000	0.675	0.842	1.037	1.282	1.646	1.962	2.330	2.581	3.098	3.300
<b>Z</b>	0.000	0.674	0.842	1.036	1.282	1.645	1.960	2.326	2.576	3.090	3.291
	0%	50%	60%	70%	80%	90%	95%	98%	99%	99.8%	99.9%
	<b>Confidence Level</b>										

PROJECT TITLE:

**OC Guelph Glass Plant - Annual Average Hexavalent Chromium Concentration  
Preferred Pollution Control Combination (ID E\_R9) from Technical Benchmarking**



PLOT FILE OF ANNUAL VALUES FOR SOURCE GROUP: ALL

MICROGRAMS/M3

Max: 2.4E-03 [MICROGRAMS/M3] at (562063.97, 4821525.92)



COMMENTS:

Reg 419 grid  
Met Year 2

SOURCES:

**10**

COMPANY NAME:

**Owens Corning Guelph Glass Plant**

RECEPTORS:

**2062**

MODELER:

**C.MacKay, LEHDER**

OUTPUT TYPE:

**Concentration**

SCALE:

1:10,000

0 0.3 km



MAX:

**2.4E-03 MICROGRAMS/M3**

DATE:

**3/19/2015**

PROJECT NO.:

**144539**

Annual Hexavalent Chromium Results  
Preferred Option - Summary of 5 year data set

Run (tab) Name:	Ann_Opt_E_R9_Metyr1	Ann_Opt_E_R9_Metyr2	Ann_Opt_E_R9_Metyr3	Ann_Opt_E_R9_Metyr4	Ann_Opt_E_R9_Metyr5	
Run Description:	Option E_R9, Reg 419 grid, Site Specific Met (2009)	Option E_R9, Reg 419 grid, Site Specific Met (2010)	Option E_R9, Reg 419 grid, Site Specific Met (2011)	Option E_R9, Reg 419 grid, Site Specific Met (2012)	Option E_R9, Reg 419 grid, Site Specific Met (2013)	<b>MAX</b>
Result Units:	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>
ALL	2.11662	2.38471	2.12615	2.19456	2.25161	2.38471
B38	1.10762	1.21329	1.13902	1.21907	1.30165	1.30165
B10	0.05166	0.05303	0.05319	0.05381	0.05314	0.05381
B32	0.10545	0.11196	0.104	0.10709	0.10604	0.11196
B34	0.07842	0.08919	0.07613	0.08062	0.07885	0.08919
B35	0.0783	0.09035	0.07616	0.08169	0.07834	0.09035
C79	0.1094	0.14398	0.10188	0.11608	0.10601	0.14398
C80	0.10431	0.1442	0.0961	0.11224	0.09545	0.1442
B24	0.25232	0.2487	0.25864	0.24412	0.26899	0.26899
B25	0.17283	0.18459	0.17381	0.16453	0.18086	0.18459
B33	0.11544	0.14794	0.10557	0.115	0.10744	0.14794
FURNACE	0.42515	0.4333	0.43245	0.40865	0.44985	0.44985
FOREHEAR	1.10762	1.21329	1.13902	1.21907	1.30165	1.30165
GENEXHTS	0.62718	0.76247	0.59689	0.6495	0.61285	0.76247

Run Description:	Option E_R9, Reg 419 grid, Site Specific Met (2009)	Option E_R9, Reg 419 grid, Site Specific Met (2010)	Option E_R9, Reg 419 grid, Site Specific Met (2011)	Option E_R9, Reg 419 grid, Site Specific Met (2012)	Option E_R9, Reg 419 grid, Site Specific Met (2013)	<b>MAX</b>
Result Units:	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>
ALL	0.00211662	0.00238471	0.00212615	0.00219456	0.00225161	0.002385
B38	0.00110762	0.00121329	0.00113902	0.00121907	0.00130165	0.001302
B10	0.00005166	0.00005303	0.00005319	0.00005381	0.00005314	5.38E-05
B32	0.00010545	0.00011196	0.000104	0.00010709	0.00010604	0.000112
B34	0.00007842	0.00008919	0.00007613	0.00008062	0.00007885	8.92E-05
B35	0.0000783	0.00009035	0.00007616	0.00008169	0.00007834	9.04E-05
C79	0.0001094	0.00014398	0.00010188	0.00011608	0.00010601	0.000144
C80	0.00010431	0.0001442	0.0000961	0.00011224	0.00009545	0.000144
B24	0.00025232	0.0002487	0.00025864	0.00024412	0.00026899	0.000269
B25	0.00017283	0.00018459	0.00017381	0.00016453	0.00018086	0.000185
B33	0.00011544	0.00014794	0.00010557	0.000115	0.00010744	0.000148
FURNACE	0.00042515	0.0004333	0.00043245	0.00040865	0.00044985	0.00045
FOREHEAR	0.00110762	0.00121329	0.00113902	0.00121907	0.00130165	0.001302
GENEXHTS	0.00062718	0.00076247	0.00059689	0.0006495	0.00061285	0.000762

# Source Pathway - Source Inputs

AERMOD

## Point Sources

Source Type	Source ID	X Coordinate [m]	Y Coordinate [m]	Base Elevation (Optional) [m]	Release Height [m]	Emission Rate [g/s]	Gas Exit Temp. [K]	Gas Exit Velocity [m/s]	Stack Inside Diameter [m]
POINT	B10	562030.25	4821525.28	312.00	14.45	9.08E-7	321.90	12.10	1.24
		General Exhaust Above T107B F/H							
POINT	B32	562047.16	4821528.02	312.00	14.48	9.08E-7	321.90	19.19	1.24
		General Exhaust Above T106							
POINT	B34	562039.70	4821535.65	312.00	14.48	9.08E-7	321.90	19.19	1.24
		General Exhaust Above T107A F/H							
POINT	B35	562047.03	4821543.82	312.00	14.48	9.08E-7	321.90	19.19	1.24
		General Exhaust Above CFM Main Channel							
POINT	C79	562023.15	4821559.58	312.00	11.64	3.10E-6	310.80	9.59	1.41
		General Exhaust West CFM F/H							
POINT	C80	562028.25	4821564.97	312.00	11.64	3.10E-6	310.80	9.59	1.41
		General Exhaust East CFM F/H							
POINT	B38	562043.48	4821544.79	312.00	28.00	0.00011	379.15	5.43	0.75
		final parameters provided to OC							
POINT	B24	562052.59	4821531.65	312.00	31.43	0.00002	597.00	15.00	0.33
		final parameters provided to OC							
POINT	B25	562057.67	4821536.90	312.00	31.43	0.00002	597.00	15.00	0.33
		final parameters provided to OC							
POINT	B33	562055.21	4821536.35	312.00	20.00	3.12E-6	321.90	30.00	0.79
		B33J uncapped, existing loc, ht=25, V=30m/s							

## Volume Sources

No Volume Sources Specified

## Area Sources

No Area Sources Specified

\*\*MODELOPTs: NonDEFAULT CONC ELEV FLGPOL BETA

\*\*\* MODEL SETUP OPTIONS SUMMARY \*\*\*

\*\*Model Is Setup For Calculation of Average CONCentration Values.

-- DEPOSITION LOGIC --

\*\*NO GAS DEPOSITION Data Provided.

\*\*NO PARTICLE DEPOSITION Data Provided.

\*\*Model Uses NO DRY DEPLETION. DRYDPLT = F

\*\*Model Uses NO WET DEPLETION. WETDPLT = F

\*\*Model Uses RURAL Dispersion Only.

\*\*Model Allows User-Specified Options:

1. Stack-tip Downwash.
2. Model Accounts for ELEVated Terrain Effects.
3. Use Calms Processing Routine.
4. Use Missing Data Processing Routine.
5. No Exponential Decay.
6. BETA Option for Capped & Horiz Stacks Selected With:

4 Capped Stack(s); and 0 Horiz Stack(s)

\*\*Other Options Specified:

CCVR\_Sub - Meteorological data includes CCVR substitutions  
TEMP\_Sub - Meteorological data includes TEMP substitutions

\*\*Model Accepts FLAGPOLE Receptor Heights.

\*\*The User Specified a Pollutant Type of: HCR

\*\*Model Calculates ANNUAL Averages Only

\*\*This Run Includes: 10 Source(s); 14 Source Group(s); and 2062 Receptor(s)

\*\*Model Set To Continue RUNning After the Setup Testing.

\*\*The AERMET Input Meteorological Data Version Date: 14134

\*\*Output Options Selected:

Model Outputs Tables of ANNUAL Averages by Receptor  
Model Outputs External File(s) of High Values for Plotting (PLOTFILE Keyword)  
Model Outputs Separate Summary File of High Ranked Values (SUMMFILE Keyword)

\*\*NOTE: The Following Flags May Appear Following CONC Values: c for Calm Hours  
m for Missing Hours  
b for Both Calm and Missing Hours

\*\*Misc. Inputs: Base Elev. for Pot. Temp. Profile (m MSL) = 325.00 ; Decay Coef. = 0.000 ; Rot. Angle = 0.0  
Emission Units = GRAMS/S ; Emission Rate Unit Factor = 0.10000E+10  
Output Units = NANOGRAMS/M3

\*\*Approximate Storage Requirements of Model = 4.5 MB of RAM.

\*\*File for Saving Result Arrays: Ann\_Opt\_E\_R9\_Metyr2.sv1

\*\*File for Summary of Results: Ann\_Opt\_E\_R9\_Metyr2.sum

\*\*MODELOPTs: NonDEFAULT CONC ELEV FLGPOL BETA

\*\*\* METEOROLOGICAL DAYS SELECTED FOR PROCESSING \*\*\*  
(1=YES; 0=NO)



\*\*\* AERMOD - VERSION 14134 \*\*\*  
\*\*\* AERMET - VERSION 14134 \*\*\*

\*\*\* OC Guelph Project 144539 - Site Specific Standard  
\*\*\* Ann\_Opt\_E\_R9\_Metry2

\*\*\* 02/23/15  
\*\*\* 07:06:26  
\*\*\* PAGE 4

\*\*MODELOPTs: NonDEFAULT CONC ELEV FLGPOL BETA

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL RESULTS AVERAGED OVER 1 YEARS \*\*\*

\*\* CONC OF HCR IN NANOGRAMS/M3 \*\*

GROUP ID	AVERAGE CONC	RECEPTOR (XR, YR, ZELEV, ZHILL, ZFLAG)	OF TYPE	NETWORK GRID-ID
B10	1ST HIGHEST VALUE IS 0.05303 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	2ND HIGHEST VALUE IS 0.05303 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	3RD HIGHEST VALUE IS 0.03800 AT ( 562076.93, 4821485.66, 310.19, 310.19, 0.00)	DC		
	4TH HIGHEST VALUE IS 0.03800 AT ( 562076.93, 4821485.66, 310.19, 310.19, 0.00)	DC		
	5TH HIGHEST VALUE IS 0.03586 AT ( 562070.22, 4821492.13, 310.40, 310.40, 0.00)	DC		
	6TH HIGHEST VALUE IS 0.03586 AT ( 562070.22, 4821492.13, 310.40, 310.40, 0.00)	DC		
	7TH HIGHEST VALUE IS 0.03541 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	8TH HIGHEST VALUE IS 0.03541 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	9TH HIGHEST VALUE IS 0.03486 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
	10TH HIGHEST VALUE IS 0.03486 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
B24	1ST HIGHEST VALUE IS 0.24870 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
	2ND HIGHEST VALUE IS 0.24870 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
	3RD HIGHEST VALUE IS 0.23024 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	4TH HIGHEST VALUE IS 0.23024 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	5TH HIGHEST VALUE IS 0.21928 AT ( 562070.91, 4821533.11, 311.00, 311.00, 0.00)	DC		
	6TH HIGHEST VALUE IS 0.21928 AT ( 562070.91, 4821533.11, 311.00, 311.00, 0.00)	DC		
	7TH HIGHEST VALUE IS 0.18708 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	8TH HIGHEST VALUE IS 0.18708 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	9TH HIGHEST VALUE IS 0.17240 AT ( 562085.76, 4821532.01, 311.00, 311.00, 0.00)	DC		
	10TH HIGHEST VALUE IS 0.16245 AT ( 562077.84, 4821540.29, 311.01, 311.01, 0.00)	DC		
B25	1ST HIGHEST VALUE IS 0.18459 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
	2ND HIGHEST VALUE IS 0.18459 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
	3RD HIGHEST VALUE IS 0.15927 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	4TH HIGHEST VALUE IS 0.15927 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	5TH HIGHEST VALUE IS 0.15868 AT ( 562070.91, 4821533.11, 311.00, 311.00, 0.00)	DC		
	6TH HIGHEST VALUE IS 0.15868 AT ( 562070.91, 4821533.11, 311.00, 311.00, 0.00)	DC		
	7TH HIGHEST VALUE IS 0.13006 AT ( 562085.76, 4821532.01, 311.00, 311.00, 0.00)	DC		
	8TH HIGHEST VALUE IS 0.12033 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	9TH HIGHEST VALUE IS 0.12033 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	10TH HIGHEST VALUE IS 0.11479 AT ( 562065.76, 4821512.01, 311.00, 311.00, 0.00)	DC		
B32	1ST HIGHEST VALUE IS 0.11196 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
	2ND HIGHEST VALUE IS 0.11196 AT ( 562063.97, 4821525.92, 311.00, 311.00, 0.00)	DC		
	3RD HIGHEST VALUE IS 0.10100 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	4TH HIGHEST VALUE IS 0.10100 AT ( 562057.04, 4821518.74, 311.00, 311.00, 0.00)	DC		
	5TH HIGHEST VALUE IS 0.09109 AT ( 562070.91, 4821533.11, 311.00, 311.00, 0.00)	DC		
	6TH HIGHEST VALUE IS 0.09109 AT ( 562070.91, 4821533.11, 311.00, 311.00, 0.00)	DC		
	7TH HIGHEST VALUE IS 0.08363 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	8TH HIGHEST VALUE IS 0.08363 AT ( 562050.10, 4821511.55, 311.00, 311.00, 0.00)	DC		
	9TH HIGHEST VALUE IS 0.05866 AT ( 562085.76, 4821512.01, 311.00, 311.00, 0.00)	DC		
	10TH HIGHEST VALUE IS 0.05805 AT ( 562065.76, 4821512.01, 311.00, 311.00, 0.00)	DC		

\*\*\* AERMOD - VERSION 14134 \*\*\*  
\*\*\* AERMET - VERSION 14134 \*\*\*

\*\*\* OC Guelph Project 144539 - Site Specific Standard  
\*\*\* Ann\_Opt\_E\_R9\_Metry2

\*\*\* 02/23/15  
\*\*\* 07:06:26  
\*\*\* PAGE 5

\*\*MODELOPTs: NonDEFAULT CONC ELEV FLGPOL BETA

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL RESULTS AVERAGED OVER 1 YEARS \*\*\*

\*\* CONC OF HCR IN NANOGRAMS/M3 \*\*

GROUP ID	AVERAGE CONC	RECEPTOR (XR, YR, ZELEV, ZHILL, ZFLAG)	OF TYPE	NETWORK GRID-ID
----------	--------------	--	---------	-----------------

B33	1ST	HI GHEST	VALUE	IS	0.14794	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI GHEST	VALUE	IS	0.14794	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI GHEST	VALUE	IS	0.12244	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	4TH	HI GHEST	VALUE	IS	0.12244	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	5TH	HI GHEST	VALUE	IS	0.11999	AT (	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	6TH	HI GHEST	VALUE	IS	0.11040	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	7TH	HI GHEST	VALUE	IS	0.11040	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	8TH	HI GHEST	VALUE	IS	0.11031	AT (	562085.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	9TH	HI GHEST	VALUE	IS	0.06974	AT (	562085.76,	4821492.01,	310.52,	310.52,	0.00)	DC
	10TH	HI GHEST	VALUE	IS	0.06889	AT (	562085.76,	4821532.01,	311.00,	311.00,	0.00)	DC
B34	1ST	HI GHEST	VALUE	IS	0.08919	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI GHEST	VALUE	IS	0.08919	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI GHEST	VALUE	IS	0.07666	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	4TH	HI GHEST	VALUE	IS	0.07666	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	5TH	HI GHEST	VALUE	IS	0.07406	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	6TH	HI GHEST	VALUE	IS	0.07406	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	7TH	HI GHEST	VALUE	IS	0.06139	AT (	562050.10,	4821511.55,	311.00,	311.00,	0.00)	DC
	8TH	HI GHEST	VALUE	IS	0.06139	AT (	562050.10,	4821511.55,	311.00,	311.00,	0.00)	DC
	9TH	HI GHEST	VALUE	IS	0.05589	AT (	562085.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	10TH	HI GHEST	VALUE	IS	0.05486	AT (	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC
B35	1ST	HI GHEST	VALUE	IS	0.09035	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI GHEST	VALUE	IS	0.09035	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI GHEST	VALUE	IS	0.07545	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	4TH	HI GHEST	VALUE	IS	0.07545	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	5TH	HI GHEST	VALUE	IS	0.07161	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	6TH	HI GHEST	VALUE	IS	0.07161	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	7TH	HI GHEST	VALUE	IS	0.06046	AT (	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	8TH	HI GHEST	VALUE	IS	0.05898	AT (	562085.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	9TH	HI GHEST	VALUE	IS	0.05420	AT (	562085.76,	4821532.01,	311.00,	311.00,	0.00)	DC
	10TH	HI GHEST	VALUE	IS	0.04152	AT (	562077.84,	4821540.29,	311.01,	311.01,	0.00)	DC
B38	1ST	HI GHEST	VALUE	IS	1.21329	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	2ND	HI GHEST	VALUE	IS	1.21329	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	3RD	HI GHEST	VALUE	IS	1.18894	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	4TH	HI GHEST	VALUE	IS	1.18894	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	5TH	HI GHEST	VALUE	IS	0.97601	AT (	562085.76,	4821532.01,	311.00,	311.00,	0.00)	DC
	6TH	HI GHEST	VALUE	IS	0.94370	AT (	562077.84,	4821540.29,	311.01,	311.01,	0.00)	DC
	7TH	HI GHEST	VALUE	IS	0.94370	AT (	562077.84,	4821540.29,	311.01,	311.01,	0.00)	DC
	8TH	HI GHEST	VALUE	IS	0.87345	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	9TH	HI GHEST	VALUE	IS	0.87345	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	10TH	HI GHEST	VALUE	IS	0.77779	AT (	562084.78,	4821547.47,	311.25,	311.25,	0.00)	DC

♀ \*\*\* AERMOD - VERSION 14134 \*\*\*  
 \*\*\* AERMET - VERSION 14134 \*\*\*

\*\*\* OC Guelph Project 144539 - Site Specific Standard  
 \*\*\* Ann\_Opt\_E\_R9\_Metryr2

\*\*\*  
 \*\*\*

02/23/15  
 07:06:26  
 PAGE 6

\*\*MODELOPTS: NonDEFAULT CONC

ELEV FLGPOL BETA

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL RESULTS AVERAGED OVER 1 YEARS \*\*\*

\*\* CONC OF HCR I N NANOGRAMS/M3 \*\*

GROUP ID AVERAGE CONC RECEPTOR (XR, YR, ZELEV, ZHILL, ZFLAG) OF TYPE NETWORK GRID-ID

C79	1ST	HI GHEST	VALUE	IS	0.14398	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI GHEST	VALUE	IS	0.14398	AT (	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI GHEST	VALUE	IS	0.12547	AT (	562085.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	4TH	HI GHEST	VALUE	IS	0.12092	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	5TH	HI GHEST	VALUE	IS	0.12092	AT (	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	6TH	HI GHEST	VALUE	IS	0.11452	AT (	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	7TH	HI GHEST	VALUE	IS	0.10708	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	8TH	HI GHEST	VALUE	IS	0.10708	AT (	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	9TH	HI GHEST	VALUE	IS	0.08593	AT (	562085.76,	4821532.01,	311.00,	311.00,	0.00)	DC
	10TH	HI GHEST	VALUE	IS	0.08321	AT (	562105.76,	4821512.01,	311.00,	311.00,	0.00)	DC



Ann\_Opt\_E\_R9\_Metyr2

C80	1ST	HI	GHEST	VALUE	IS	0.14420	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI	GHEST	VALUE	IS	0.14420	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI	GHEST	VALUE	IS	0.14226	AT	(	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	4TH	HI	GHEST	VALUE	IS	0.13260	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	5TH	HI	GHEST	VALUE	IS	0.13260	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	6TH	HI	GHEST	VALUE	IS	0.11474	AT	(	562085.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	7TH	HI	GHEST	VALUE	IS	0.09768	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	8TH	HI	GHEST	VALUE	IS	0.09768	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	9TH	HI	GHEST	VALUE	IS	0.09222	AT	(	562085.76,	4821492.01,	310.52,	310.52,	0.00)	DC
	10TH	HI	GHEST	VALUE	IS	0.08340	AT	(	562056.81,	4821505.08,	310.84,	310.84,	0.00)	DC

FURNACE	1ST	HI	GHEST	VALUE	IS	0.43330	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI	GHEST	VALUE	IS	0.43330	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI	GHEST	VALUE	IS	0.38951	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	4TH	HI	GHEST	VALUE	IS	0.38951	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	5TH	HI	GHEST	VALUE	IS	0.37796	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	6TH	HI	GHEST	VALUE	IS	0.37796	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	7TH	HI	GHEST	VALUE	IS	0.30741	AT	(	562050.10,	4821511.55,	311.00,	311.00,	0.00)	DC
	8TH	HI	GHEST	VALUE	IS	0.30741	AT	(	562050.10,	4821511.55,	311.00,	311.00,	0.00)	DC
	9TH	HI	GHEST	VALUE	IS	0.30246	AT	(	562085.76,	4821532.01,	311.00,	311.00,	0.00)	DC
	10TH	HI	GHEST	VALUE	IS	0.26144	AT	(	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC

FOREHEAR	1ST	HI	GHEST	VALUE	IS	1.21329	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	2ND	HI	GHEST	VALUE	IS	1.21329	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	3RD	HI	GHEST	VALUE	IS	1.18894	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	4TH	HI	GHEST	VALUE	IS	1.18894	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	5TH	HI	GHEST	VALUE	IS	0.97601	AT	(	562085.76,	4821532.01,	311.00,	311.00,	0.00)	DC
	6TH	HI	GHEST	VALUE	IS	0.94370	AT	(	562077.84,	4821540.29,	311.01,	311.01,	0.00)	DC
	7TH	HI	GHEST	VALUE	IS	0.94370	AT	(	562077.84,	4821540.29,	311.01,	311.01,	0.00)	DC
	8TH	HI	GHEST	VALUE	IS	0.87345	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	9TH	HI	GHEST	VALUE	IS	0.87345	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	10TH	HI	GHEST	VALUE	IS	0.77779	AT	(	562084.78,	4821547.47,	311.25,	311.25,	0.00)	DC

♀ \*\*\* AERMOD - VERSION 14134 \*\*\*  
 \*\*\* AERMET - VERSION 14134 \*\*\*

\*\*\* OC Guelph Project 144539 - Site Specific Standard  
 \*\*\* Ann\_Opt\_E\_R9\_Metyr2

\*\*\*  
 \*\*\*

02/23/15  
 07:06:26  
 PAGE 7

\*\*MODELOPTS: NonDEFAULT CONC ELEV FLGPOL BETA

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL RESULTS AVERAGED OVER 1 YEARS \*\*\*

\*\* CONC OF HCR IN NANOGRAMS/M3 \*\*

GROUP ID						AVERAGE CONC						RECEPTOR (XR, YR, ZELEV, ZHILL, ZFLAG)	OF TYPE	NETWORK GRID-ID
GENEXHTS	1ST	HI	GHEST	VALUE	IS	0.76247	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI	GHEST	VALUE	IS	0.76247	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI	GHEST	VALUE	IS	0.64680	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	4TH	HI	GHEST	VALUE	IS	0.64680	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	5TH	HI	GHEST	VALUE	IS	0.60412	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	6TH	HI	GHEST	VALUE	IS	0.60412	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	7TH	HI	GHEST	VALUE	IS	0.56747	AT	(	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	8TH	HI	GHEST	VALUE	IS	0.53483	AT	(	562085.76,	4821512.01,	311.00,	311.00,	0.00)	DC
	9TH	HI	GHEST	VALUE	IS	0.43243	AT	(	562050.10,	4821511.55,	311.00,	311.00,	0.00)	DC
	10TH	HI	GHEST	VALUE	IS	0.43243	AT	(	562050.10,	4821511.55,	311.00,	311.00,	0.00)	DC
ALL	1ST	HI	GHEST	VALUE	IS	2.38471	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	2ND	HI	GHEST	VALUE	IS	2.38471	AT	(	562063.97,	4821525.92,	311.00,	311.00,	0.00)	DC
	3RD	HI	GHEST	VALUE	IS	2.19537	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	4TH	HI	GHEST	VALUE	IS	2.19537	AT	(	562070.91,	4821533.11,	311.00,	311.00,	0.00)	DC
	5TH	HI	GHEST	VALUE	IS	1.90976	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	6TH	HI	GHEST	VALUE	IS	1.90976	AT	(	562057.04,	4821518.74,	311.00,	311.00,	0.00)	DC
	7TH	HI	GHEST	VALUE	IS	1.67730	AT	(	562085.76,	4821532.01,	311.00,	311.00,	0.00)	DC
	8TH	HI	GHEST	VALUE	IS	1.52625	AT	(	562077.84,	4821540.29,	311.01,	311.01,	0.00)	DC
	9TH	HI	GHEST	VALUE	IS	1.52625	AT	(	562077.84,	4821540.29,	311.01,	311.01,	0.00)	DC
	10TH	HI	GHEST	VALUE	IS	1.51423	AT	(	562065.76,	4821512.01,	311.00,	311.00,	0.00)	DC

2.3847 ng/m3 = 0.0023847 ug/m3

\*\*\* RECEPTOR TYPES: GC = GRIDCART  
GP = GRIDPOLR  
DC = DISCCART  
DP = DISCPOLR

\*\*\* AERMOD - VERSION 14134 \*\*\* \*\*\* OC Guelph Project 144539 - Site Specific Standard  
\*\*\* AERMET - VERSION 14134 \*\*\* \*\*\* Ann\_Opt\_E\_R9\_Metyr2

\*\*\* 02/23/15  
\*\*\* 07:06:26  
\*\*\* PAGE 8

\*\*MODELOPTs: NonDEFAULT CONC ELEV FLGPOL BETA

\*\*\* Message Summary : AERMOD Model Execution \*\*\*

----- Summary of Total Messages -----


A Total of 0 Fatal Error Message(s)  
A Total of 0 Warning Message(s)  
A Total of 3 Informational Message(s)  
  
A Total of 8760 Hours Were Processed  
  
A Total of 3 Calm Hours Identified  
  
A Total of 0 Missing Hours Identified ( 0.00 Percent)

\*\*\*\*\* FATAL ERROR MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\* WARNING MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

PROJECT TITLE:


**OC Guelph Glass Plant -Sensitive Receptor Assessment  
Preferred Pollution Control Combination (ID E\_R9) from Technological Benchmarking**



PLOT FILE OF ANNUAL VALUES FOR SOURCE GROUP: ALL

MICROGRAMS/M3

Max: 6.3E-04 [MICROGRAMS/M3] at (561865.76, 4821572.01)



<p>COMMENTS:</p> <p>Sensitive Receptor Grid Met Year 1 Red Triangle = Max POI Concentration Black Circle = Concentration at the location</p>	<p>SOURCES:</p> <p><b>10</b></p>	<p>COMPANY NAME:</p> <p><b>Owens Corning Guelph Glass Plant</b></p>	
	<p>RECEPTORS:</p> <p><b>801</b></p>	<p>MODELER:</p> <p><b>C. Mackay, LEHDER</b></p>	
	<p>OUTPUT TYPE:</p> <p><b>Concentration</b></p>	<p>SCALE: 1:8,000</p> <p>0  0.3 km</p>	
	<p>MAX:</p> <p><b>6.3E-04 MICROGRAMS/M3</b></p>	<p>DATE:</p> <p><b>3/23/2015</b></p>	<p>PROJECT NO.:</p> <p><b>144539</b></p>

Annual Hexavalent Chromium concentrations  
 Technical Benchmarking - Preferred Option E\_R9 - Sensitive Receptor Modeling - 5 year data set

Run (tab) Name:	Ann_Opt_E_R9_AllSR_R1_yr1	Ann_Opt_E_R9_AllSR_R1_yr2	Ann_Opt_E_R9_AllSR_R1_yr3	Ann_Opt_E_R9_AllSR_R1_yr4	Ann_Opt_E_R9_SRAll_R1_yr5	
Run Description:	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2009)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2010)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2011)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2012)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2013)	<b>MAX</b>
Result Units:	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>	<b>ng/m3</b>
ALL	0.63103	0.4272	0.58772	0.49976	0.58243	<b>0.63103</b>
B38	0.42566	0.28611	0.39354	0.33433	0.38774	<b>0.42566</b>
B10	0.00459	0.00355	0.00471	0.004	0.00468	<b>0.00471</b>
B32	0.00356	0.00248	0.00321	0.00284	0.00317	<b>0.00356</b>
B34	0.00356	0.00246	0.00322	0.00264	0.00296	<b>0.00356</b>
B35	0.00351	0.00284	0.0036	0.00285	0.00312	<b>0.0036</b>
C79	0.01508	0.01326	0.01519	0.01207	0.0122	<b>0.01519</b>
C80	0.01266	0.01128	0.01267	0.01153	0.01259	<b>0.01267</b>
B24	0.08456	0.05764	0.07746	0.0675	0.07923	<b>0.08456</b>
B25	0.07617	0.05175	0.07043	0.05924	0.07064	<b>0.07617</b>
B33	0.01128	0.00812	0.01061	0.00924	0.00961	<b>0.01128</b>
FURNACE	0.16073	0.10939	0.14789	0.12652	0.14987	<b>0.16073</b>
FOREHEAR	0.42566	0.28611	0.39354	0.33433	0.38774	<b>0.42566</b>
GENEXHTS	0.05004	0.04062	0.04918	0.04254	0.04482	<b>0.05004</b>

Run Description:	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2009)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2010)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2011)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2012)	Option E_R9_AllSR_R1, Reg 419 grid, Site Specific Met (2013)	<b>MAX</b>
Result Units:	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>	<b>ug/m3</b>
ALL	0.00063103	0.0004272	0.00058772	0.00049976	0.00058243	<b>0.000631</b>
B38	0.00042566	0.00028611	0.00039354	0.00033433	0.00038774	<b>0.000426</b>
B10	0.0000459	0.0000355	0.0000471	0.00004	0.0000468	<b>4.71E-06</b>
B32	0.0000356	0.0000248	0.0000321	0.0000284	0.0000317	<b>3.56E-06</b>
B34	0.0000356	0.0000246	0.0000322	0.0000264	0.0000296	<b>3.56E-06</b>
B35	0.0000351	0.0000284	0.000036	0.0000285	0.0000312	<b>3.6E-06</b>
C79	0.0001508	0.0001326	0.0001519	0.0001207	0.000122	<b>1.52E-05</b>
C80	0.0001266	0.0001128	0.0001267	0.0001153	0.0001259	<b>1.27E-05</b>
B24	0.0008456	0.0005764	0.0007746	0.000675	0.0007923	<b>8.46E-05</b>
B25	0.0007617	0.0005175	0.0007043	0.0005924	0.0007064	<b>7.62E-05</b>
B33	0.0001128	0.0000812	0.0001061	0.0000924	0.0000961	<b>1.13E-05</b>
FURNACE	0.0016073	0.0010939	0.0014789	0.0012652	0.0014987	<b>0.000161</b>
FOREHEAR	0.00042566	0.00028611	0.00039354	0.00033433	0.00038774	<b>0.000426</b>
GENEXHTS	0.0005004	0.0004062	0.0004918	0.0004254	0.0004482	<b>5E-05</b>